

MODEL LA-16

CAUTION:

STANDBY BATTERIES ARE CAPABLE OF SUPPLYING VERY LARGE AMOUNTS OF CURRENT IF THEIR LEADS ARE SHORTED. THAT AMOUNT OF CURRENT COULD MELT AND DAMAGE THE INSULATION.

LBNL ELECTRICAL STANDARDS	DRAWN BY	DATE
	CHECKED BY	
FIRE ALARM SYSTEM	APPROVED BY	
MODEL LA-16	CAD FILE PATH	
MODEL LA-10	SCALE NTS	
UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY	DRAWING NO.	SHEET
FACILITIES DIVISION	FA103	
TAGILITIES DIVISION	PROJECT NO.	1